GMR Kamalanga Energy Limited



AT/PO: Kamalanga, PS: Kantabania. VIA: Meramundali, DIST: Dhenkanal - 759 121, Odisha CIN U40101KA2007PLC044809

T +91 6762 663564

W www.gmrgroup.in 31-64/2 4

Ref: GKEL/MOEF&CC/2024-25/8312

Date: 24.05.2024

To

The Director Eastern Regional Office

Ministry of Environment, Forests & Climate Change, Govt. of India A/3, Chandrasekharpur, Bhubaneswar, Odisha - 751023

Submission of 33rd Half-Yearly EC Compliance Status Report of 1050 (3x350) MW, TPP at Sub:

Village Kamalanga, Dhenkanal District, Odisha.

Env. Clearance vides your letter No. J-13011/64/2007-IA.II (T) dated 5th February 2008 Ref:

Dear Sir,

With reference to the subject referred above, we are pleased to submit the 33rd Half Yearly EC Compliance Status Report of our 1050 (3x350) MW Thermal Power Plant at village Kamalanga, Dhenkanal District, Odisha, for your kind perusal please.

Kindly acknowledge receipt of the same.

Thanking You,

Yours Sincerely, for GMR Kamalanga Energy Limited,

Plant Head

Encl. - As above

Copy for kind information to:

- 1) Director, MoEF&CC, GOI, New Delhi
- 2) Regional Director, CPCB Zonal Office, Kolkata
- 3) Member Secretary, SPCB Odisha, Bhubaneswar
- 4) Regional Officer, SPCB Odisha, Hakimpada, Angul

EC Compliance Report

Name of the project : GMR Kamalanga Energy Limited, Dhenkanal, Odisha

Clearance Letter No. & Date : J_13011/64/2007-IA. II(T) dated 5th Feb 2008 (Phase-I: 3x350MW)

Period of Compliance Report : October 2023 to March 2024

SI.	CONDITIONS	COMPLIANCE STATUS
1	The total land requirement shall not exceed 1050 Acres for all the activities / facilities of the power project. Revised Land requirement of the project is 1158.57 Acres as per the MoEF &CC, New Delhi vide amendment letter dated 11.01.2019.	Presently 1158.57 Acres of land is in use.
2	It shall be ensured that the project boundary is at least 500 m away from HFL of the river in conformity with the guideline in this regard.	Complied. The distance of Brahmani River from the plant boundary is > 1.5KM.
3	The plant heat rate of around 2300 kcal/kwh shall be achieved and the coal consumption shall not exceed 660 tph.	Avg. Heat Rate – 2308.93 kcl/kwh Avg. Coal Consumption – 654.26 tph
4	Ash and Sulphur contents in the coal to be used in the project shall not exceed 34% and 0.5 % respectively.	Ash and Sulphur content of fired coal are as below during compliance period Ash content – 44.52 % Sulphur content- 0.45 %
5	A multi–flue stack of 275 m height with exit velocity of not less than 21 m/s shall be provided with continuous online monitoring system.	Complied Velocity is being maintained as specified.
6	High efficiency Electrostatic precipitators (ESPs) with efficiency not less than 99.9% shall be installed so as to ensure that particulate emissions do not exceed 50 mg/Nm ³ .	
7	Appropriate mitigation measures shall be adopted to reduce the emissions of SO_2 . It shall be ensured that at no point of time the ground level concentration of SO_2 in the impact zone exceeds the prescribed limit. The proponent shall now itself also provide space for installation of FGD or other suitable measures, if required at a later stage.	 ▶ Being complied, ▶ GLC of SO₂ in impact zone was found within the prescribed limit. Monitoring report is being submitted quarterly. ▶ Space provided for FGD
8	Water requirement shall not exceed 37 cusecs. No ground water shall be extracted for the project at any stage including during construction.	Complied. Water from river Brahmani is being used for operational activity, as per the approval.
9	COC of not less than 5 shall be adopted. Specific water consumption shall be 3.5m³/mw as per the Ministry's Notification dated 07.12.2015	Complied The avg. COC of last six months is 7.00 and Specific water consumption is 2.10 m³/MW.
10	Closed circuit cooling system with induced draft cooling towers shall be provided.	Complied
11	Waste water generated shall be recycled and reused in the plant premises. There shall be no discharge of waste water outside the plant boundary except during monsoon.	Complied.
12	For controlling fugitive dust, regular sprinkling of water in the coal handling area and other vulnerable areas of the plant shall be ensured.	Being complied. Regular water spraying being done in coal handling and other dust vulnerable areas of the plant.



13	leaching into ground water. The ash dyke shall be so designed	Noted & Being complied. Dry fly ash collection facilities and HCSD system are in place. Ash generation & utilization status for the year 2023-24 (H-2) are as follow: - Total Ash generated = 12,81,526 MT Total Ash utilisation = 12,81,526 MT % of utilisation = 100 Complied.
	and strengthened to ensure guard against breaching. Adequate safety measures shall also be taken so that pond ash does not become air borne to cause air pollution in the surrounding areas.	
15	R & R plan for land oustees and homestead oustees shall be prepared in consultation with the state Revenue Authorities prepared before starting work on the project & implemented simultaneously with the start of development/ construction work on the project. A copy of the R&R plan shall also be submitted to this ministry within three months of the issue of this letter.	R&R Plan is not applicable to our project as there are no land oustees from the project area.
16	The District collector / Revenue Divisional commissioner shall be informed regarding R&R and all other benefits to be provided by the project proponent and their effective implementation shall be overseen by the District authorities.	Being Complied. Rehabilitation & periphery development Advisory committee (RPDAC) is overseeing this implementation.
17	Rain water harvesting should be adopted. Central Ground water Authority/Board shall be consulted for finalization of appropriate rain water harvesting technology within a period of three month from the date of clearance.	Rain water harvesting (RWH) system is in operation. Rain water harvesting plan already submitted to CGWA.
18	Regular monitoring of ground water quality including heavy metals shall be undertaken around ash dyke the project area to ascertain the change, if any water quality due to leaching of contaminants from ash disposal area.	Complied.
20	A greenbelt shall be developed all along the plant and ash pond boundary covering total area of at least 320 acres. First aid and sanitation arrangements shall be made for the	 ➢ Green belt with Indigenous species already developed. We have planted around 3,97,668 saplings till March 2023 (including 2360 saplings in 2023-24) in around plant & township premises, avenue plantation along the Railway line & approach Road to cover land area of 358.303 Acres. ➢ Survival rate is around 90%. ➢ Under social voluntary project- Sabujima (A Green Initiative), 160 Nos. of fruit bearing trees were planted along with organic farming in the campus of Kamalanga Nodal High School, at Kamalanga Village. ➢ In addition to this, we have also developed avenue plantation and green belt in Dhenkanal area as required by District Administration. Complied.
20	drivers and other contract workers during construction phase.	Compiled.
		S GAR S

Monitoring report of Environmental Parameters like Stack Emission, AAQ, Effluent quality & Drinking water analysis report is enclosed as **Annexure-1**.

isiontek Consultancy Services Pvt

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018

Accredited by: NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

- OSurface & Sub-Surface Investigation
- OQuality Control & Project Management
- O Renewable Energy
- O Agricultural Development
- Oinformation Technology
- O Public Realth Engineering
- O Mine Planning & Design
- O Mineral/Sub-Soil Exploration

O Waste Management Services

Laboratory Service Environment Lab Food Lab Material Lab Mineral Lab Wicrobiology Lab

Ref: Envlab/23-24/TR- 00357

Date: 30.03.2024

AMBIENT AIR QUALITY MONITORING REPORT FOR MARCH-2024 (CORE ZONE)

1. Name of the Industry

O Infrastructure Enginering

O Water Resource Management

O Environmental & Social Study

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

Monitoring Instruments

: RDS (APM 460 BL), FPS (APM 550) Envirotech, CO Analyzer, VOC Sampler

Sampling Location

: AAQMS-1: Near Rain Water pump House Pit

Sample Collected By

: VCSPL Representative in presence of Client's Representative

D]	PARAMI	ETERS					
Date	PM ₁₀ (μg/m ³)	PM _{2.5} (μg/m ³)	SO ₂ (μg/m³)	NOx (μg/m³)	Ο ₃ (μg/m ³)	CO (mg/m³)	NH ₃ (μg/m³)	Pb (µg/m³)	Ni (ng/m³)	As (ng/m³)	С ₆ Н ₆ (µg/m ³)	BaP (ng/m³)
04.03.2024	53.2	27.7	16.1	27.8	9.5	0.55	23.6	BDL	BDL	BDL	BDL	BDL
07.03.2024	50.5	27.2	16.7	27.3	10.3	0.61	22.3	BDL	BDL	BDL	BDL	BDL
11.03.2024	50.5	27.5	15.5	26.5	9.3	0.58	23.3	BDL	BDL	BDL	BDL	BDL
14.03.2024	54.3	29.3	16.8	27.2	9.6	0.68	BDL	BDL	BDL	BDL	BDL	BDL
18.03.2024	51.6	28.3	15.5	27.1	9.5	0.65	25.8	BDL	BDL	BDL	BDL	BDL
21.03.2024	50.8	27.8	16.1	25.3	9.7	0.52	BDL	BDL	BDL	BDL	BDL	BDL
25.03.2024	50.7	27.3	16.5	24.2	9,3	0.66	24.2	BDL	BDL	BDL	BDL	BDL
28.03.2024	50.5	26.2	17.6	23.6	9.5	0.63	23.8	BDL	BDL	BDL	BDL	BDL
Monthly Average	51.5	27.7	16.4	26.1	9.6	0.6	23.8	BDL	BDL	BDL	BDL	BDL
CPCB, New Delhi AAQ Standard	100	60	80	80	100	4	400	1	20	6	5	1
TEST METHOD	Gravimetric IS 5182: Part 23	Gravimetric EPA 1998	Method S 5182 (Part 2) RA2017	6) RA2017	3rd Edn.By	Non Dispersive Infrared Method IS 5182 (Part- 10):1999	Indo Phenol Blue Method Air Sampling , 3rd Edn.By James P. Lodge (Method- 401)		AAS Method IS 5182(Part -22):2004		Gas Chromatog raphy IS 5182 (Part- 11):2006	Solvent Extraction IS 5182 (Part- 12):2004

BDL Values: $SO_2 < 4 \mu g/m^3$, $NO_X < 6 \mu g/m^3$, $O_3 < 5 \mu g/m^3$, $NH_3 < 20 \mu g/m^3$, $Ni < 0.01 ng/m^3$, $As < 0.001 ng/m^3$, $C_6H_6 < 0.001 \mu g/m^3$ BaP<0.002 ng/m³, Pb<0.001 μg/m³, CO-<0.1 mg/m³







O Infrastructure Enginering

O Water Resource Management

O Environmental & Social Study

isiontek Consultancy Services Pvt. Ltd.

(Committed For Better Environment)

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018
Accredited by: NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

OSurface & Sub-Surface Investigation

Quality Control & Project Management

O Renewable Energy

O Agricultural Development

Oleformation Technology
OPublic Health Engineering

○ Mine Planning & Design ○ Mineral/Sub-Soil Exploration

Waste Management Services

Laboratory Services
Environment Lab
Food Lab
Material Lab
Soil Lab
Mineral Lab
&
Microbiology Lab

Ref: Envlab/23-24/TR- 00358

Date: 30.03.2024

AMBIENT AIR QUALITY MONITORING REPORT FOR MARCH-2024 (CORE ZONE)

1. Name of the Industry

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

2. Monitoring Instruments

: RDS (APM 460 BL), FPS (APM 550) Envirotech, CO Analyzer, VOC Sample

Sampling Location

: AAQMS-2: Near Security Watch Tower - 3

4. Sample Collected By

: VCSPL Representative in presence of Client's Representative

					P	ARAMET	ERS					
Date	PM ₁₀ (µg/m³)	PM _{2.5} (μg/m ³)	SO ₂ (μg/m ³)	NOx (μg/m³)	Ο ₃ (μg/m³)	CO (mg/m³)	NH ₃ (μg/m ³)	Pb (μg/m³)	Ni (ng/m³)	As (ng/m³)	С ₆ Н ₆ (µg/m³)	BaP (ng/m³)
04.03.2024	52.8	31.5	16.4	27.1	9.5	0.54	BDL	BDL	BDL	BDL	BDL	BDL
07.03.2024	51.1	30.8	15.8	23.8	9.8	0.62	21.8	BDL	BDL	BDL	BDL	BDL
11.03.2024	51.6	32.2	15.5	23.8	9.4	0.58	21.7	BDL	BDL	BDL	BDL	BDL
14.03.2024	53.1	30.1	15.9	23.8	9.6	0.56	22.8	BDL	BDL	BDL	BDL	BDL
18.03.2024	49.8	29.1	16.5	24.9	9.7	0.55	BDL	BDL	BDL	BDL	BDL	BDL
21.03.2024	51.2	28.8	16.5	26.1	9.4	0.62	23.6	BDL	BDL	BDL	BDL	BDL
25.03.2024	52.5	27.5	17.2	22.4	9.8	0.55	22.8	BDL	BDL	BDL	BDL	BDL
28.03.2024	50.8	25.3	15.8	24.4	10.1	0.56	25.2	BDL	BDL	BDL	BDL	BDL
Monthly Average	51.6	29.4	16.2	24.5	9.7	0.6	23.0	BDL	BDL	BDL	BDL	BDL
CPCB, New Delhi AAQ Standard	100	60	80	80	100	4	400	1	20	6	5	1
TEST METHOD	Gravimetric IS 5182: Part 23	Gravimetric EPA 1998	& Geake Method IS 5182 (Part- 2) RA2017	IS 5182 (Part-6) RA2017	Air Sampling . 3rd Edn.By James P. Lodg (Method-411)	10):1999	Indo Phenol Blue Method Air Sampling . 3rd Edn.By James P. Lodge (Method- 401)	IS 513	AAS Method 82(Part -22):	2004	Gas Chromatog raphy 18 5182 (Part- 11):2006	Solvent Extraction IS 5182 (Part- 12):2004

BDL Values: $SO_2 < 4 \mu g/m^3$, $NO_X < 6 \mu g/m^3$. $O_3 < 5 \mu g/m^3$. $NH_3 < 20 \mu g/m^3$, $Ni < 0.01 ng/m^3$. As $< 0.001 ng/m^3$. $C_6H_6 < 0.001 \mu g/m^3$. $BaP < 0.002 ng/m^3$. $Pb < 0.001 \mu g/m^3$, $CO < 0.1 mg/m^3$







O Infrastructure Engineeing

O Environmental & Social Study

isiontek Consultancy Services Pvt. Ltd.

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018

Accredited by : NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

- O Surface & Sub-Surface Investigation O Water Resource Management
 - OQuality Control & Project Management
 - O Renewable Energy
- OAgricultural Development
- Olaformation Technology
- O Public Health Engineering
- O Mine Planning & Design
- O Mineral/Sub-Soil Exploration
- O Waste Management Services

Food Lab Material Lab Soil Lab Mineral Lab dicrobiology Lab

Ref: Envlab/23-24/TR-00359

Date: 30.03.2024

AMBIENT AIR QUALITY MONITORING REPORT FOR MARCH -2024 (CORE ZONE)

1. Name of the Industry

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

Monitoring Instruments

: RDS (APM 460 BL), FPS (APM 550) Envirotech, CO Analyzer, VOC Sampler : AAQMS-3: Near Budhapanka Material Gate(Security Watch Tower No.1)

Sampling Location Sample Collected By

: VCSPL Representative in presence of Client's Representative

					F	ARAMI	ETERS					
Date	РМ ₁₀ (µg/m ³)	PM _{2.5} (μg/m ³)	SO ₂ (µg/m³)	NOx (μg/m³)	Ο ₃ (μg/m ³)	CO (mg/m³)	NH ₃ (μg/m ³)	Pb (μg/m³)	Ni (ng/m³)	As (ng/m³)	С ₆ Н ₆ (µg/m ³)	BaP (ng/m³)
04.03.2024	54.8	30.0	17.6	25.3	8.8	0.65	22.8	BDL	BDL	BDL	BDL	BDL
07.03.2024	53.9	28.8	17.6	26.1	9.1	0.58	22.7	BDL	BDL	BDL	BDL	BDL
11.03.2024	53.3	30.1	17.5	26.3	9.2	0.61	21.6	BDL	BDL	BDL	BDL	BDL
14.03.2024	53.8	29.3	16.5	26.4	9.5	0.56	BDL	BDL	BDL	BDL	BDL	BDL
18.03.2024	53.1	28.5	17.5	24.9	9.8	0.66	25.6	BDL	BDL	BDL	BDL	BDL
21.03.2024	53.2	28.1	17.1	25.5	10.1	0.61	BDL	BDL	BDL	BDL	BDL	BDL
25.03.2024	51.8	28.2	17.8	24.8	9.8	0.54	24.8	BDL	BDL	BDL	BDL	BDL
28.03.2024	50.6	28.4	16.8	26.2	8.6	0.58	BDL	BDL	BDL	BDL	BDL	BDL
Monthly Average	53.1	28.9	17.3	25.7	9.4	0.6	23.5	BDL	BDL	BDL	BDL	BDL
CPCB, New Delhi AAQ Standard	100	60	80	80	100	4	400	1	20	6	5	1
TEST METHOD	Gravimetric IS 5182: Part 23	Gravimetric EPA 1998	improved Wes & Geake Method IS 5182 (Part- 2) RA2017	Method IS 5182 (Part- 6) RA2017	Method Air Sampling	Non Dispersive Infrared Method IS 5182 (Part- 10):1999	Indo Phenol Blue Method Air Sampling , 3rd Edn.By James P. Lodge (Method-401)		AAS Method IS 5182(Part -22):2004		Gas Chromatog raphy IS 5182 (Part- 11):2006	Solvent Extraction IS 5182 (Part- 12):2004

BDL Values: SO₂< 4 μg/m³, NO_X< 6 μg/m³, O₃<5 μg/m³, NH₃<20 μg/m³, Ni<0.01 ng/m³, As < 0.001 ng/m³, C₆H₆<0.001 μg/m³. BaP<0.002 ng/m 3 , Pb<0.001 μ g/m 3 , CO-<0.1 mg/m 3







(Committed For Better Environment)

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018
Accredited by: NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

- OSurface & Sub-Surface Investigation
- Quality Control & Project Management
- O Renewable Energy
- O Agricultural Development
- Oluformation Technology OPublic Health Engineering
- Mine Planning & Design
 Mineral/Sub-Soll Exploration
- O Waste Management Services

ion & Microbiology Lab

Laboratory Service

Environment Lab Food Lab

Material Lab Soil Lab

Ref: Envlab/23-24/TR- 00360

Date: 30.03.2024

AMBIENT AIR QUALITY MONITORING REPORT FOR MARCH -2024 (BUFFER ZONE)

1. Name of the Industry

Olnfrastructure Enginering

O Water Resource Management

O Environmental & Social Study

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

2. Monitoring Instruments

: RDS (APM 460 BL), FPS (APM 550) Envirotech, CO Analyzer, VOC Sampler

3. Sample Collected By

: VCSPL Representative in presence of Client's Representative

Location							PARAME	TERS					
Name	Date	PM ₁₀ (μg/m ³)	PM _{2.5} (μg/m ³)	SO ₂ (µg/m ³)	NOx (μg/m³)	O ₃ (µg/m ³)	CO (mg/m ³)	NH ₃ (μg/m ³)	Pb (μg/m³)	Ni (ng/m³)	As (ng/m³)	C ₆ H ₆ (μg/m ³)	BaP (ng/m³)
AAQMS1: Kamalanga (Township)	12.03.2024	51.5	27.6	15.5	26.6	8.1	0.44	21.8	BDL	BDL	BDL	BDL	BDL
AAQMS-2: Mangalpur	13.03.2024	52.2	28.5	16.5	26.6	8.2	0.48	23.6	BDL	BDL	BDL	BDL	BDL
AAQMS3: Budhapanka	14.03.2024	50.9	27.3	14.8	25.6	8.3	0.55	21.8	BDL	BDL	BDL	BDL	BDL
AAQMS4: Bhogamunda	15.03.2024	50.8	26.2	13.2	24.8	8.2	0.64	22.2	BDL	BDL	BDL	BDL	BDL
	v Delhi AAQ ndard	100	60	80	80	100	4	400	1	20	6	5	1
TEST METHOD		Gravimet ric IS 5182: Part 23	Gravimet ric EPA 1998	improved West & Geake Method IS 5182 (Part-2) RA2017	Modified Jacob &Hochheiser Method IS 5182 (Part- 6) RA2017	Chemical Method Air Sampling, 3rd Edn.By James P, Lodge (Method- 411)	Non Dispersiv e Infrared Method IS 5182 (Part- 10):1999	Indo Phenol Blue Method Air Sampling, 3rd Edn.By James P. Lodge (Method- 401)		AAS Methor 32(Part -22)		Gas Chromato graphy IS 5182 (Part- 11):2006	Solvent Extraction IS 5182 (Part- 12):2004

BDL Values: $SO_2 < 4 \mu g/m^3$, $NO_3 < 6 \mu g/m^3$, $O_3 < 5 \mu g/m^3$, $NH_3 < 20 \mu g/m^3$, $Ni < 0.01 ng/m^3$, $As < 0.001 ng/m^3$, $C_6H_6 < 0.001 \mu g/m^3$, $BaP < 0.002 ng/m^3$, $Pb < 0.001 \mu g/m^3$, $CO < 0.1 mg/m^3$, $CO < 0.1 mg/m^3$, $CO < 0.01 ng/m^3$, C







Infrastructure Enginering

· Water Resource Management

· Environmental & Social Study

isiontek Consultancy Services Pvt. Ltd.
(Committed For Better Environment)

(Laboratory Services)

Certified for : ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Accredited by : NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

- Surface & Sub-Surface Investigation
- · Quality Control & Project Management
- · Renewable Energy
- Agricultural Development
- · Information Technology
- · Public Health Engineering
- · Mine Planning & Design
- Mineral/Sub-Soil Exploration
- Waste Management Services

Laboratory Services Environment Lab Food Lab Material Lab Soil Lab Mineral Lab Microbiology Lab

Ref: Envlab/23-24/TR-00361

Date: 30.03.2024

SOURCE EMISSION MONITORING REPORT MARCH-2024

1. Name of Industry

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

2. Sampling Location

: ST-1: Stack attached to ESP Outlet of UNIT-1

: ST-2: Stack attached to ESP Outlet of UNIT-2 : ST-3 : Stack attached to ESP Outlet of UNIT-3

3. Date of Sampling

: 11.03.2024

4. Date of Analysis

: 12.03.2024 to 18.03.2024

5. Sample Collected by

: VCSPL Representative in presence of GMR representative

SI.	Parameters	Unit of	Standard as per MoEF&	Analysis Results					
.10.		Measurement	CC & CPCB	ST-1	ST-2	ST-3			
	Sampling	Date		11.03.2024	11.03.2024	11.03.2024			
1.	Stack Temperature	°C	_	128	134	138			
2.	Velocity	m/sec		25.8	21.5	26.4			
3.	Volume of Flue gas	m³/hour	•	2126756.0	1772296.7	2176215.5			
4.	Particulate Matter as PM	mg/Nm³	50.0	35.8	42.1	31.9			
5.	Sulphur Dioxide as SO ₂	mg/Nm³	600.0	1286	1363	1328			
6.	Oxides of Nitrogen as NOx	mg/Nm³	450.0	416	397	427			
7.	Carbon Monoxide as CO	mg/Nm³		10.2	9.8	10.8			
8.	Carbon Dioxide as CO ₂	%	one-sast	13.2	13.3	13.7			
9.	Oxygen as O ₂	%		6.5	7.2	6.3			
10.	Mercury as Hg	mg/Nm³	0.03	0.0168	0.0152	0.0177			

are corrected @6% O2 level in flue gas emission

isiontek Consultancy Services Pvt. Ltd. (Committed For Better Environment) (Laborator Services)

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018

Accredited by: NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

O Infrastructure Enginering O Water Resource Management O Environmental & Social Study

OSurface & Sub-Surface Investigation O Quality Control & Project Management

CRenewable Energy

O Agricultural Development Obsformation Technology

O Mine Planning & Design O Mineral/Sub-Soli Exploration OPublic Health Engineering

O Waste Management Services

Laboratory Services Food Cab Material Lab Soil Lab Mineral Lab Microbiology Lab

Ref: Envlab/23-24/TR-00362

Date:30.03.2024

DRINKING WATER ANALYSIS REPORT MARCH-2024

1. Name of the Industry

2. Sampling Location : M/s GMR Kamalanga Energy Ltd, Dhenkanal : DW1: Potable Drinking Water Before Treatment DW2: Potable Drinking Water After Treatment

3. Date of Sampling : 11.03.2024

4. Date of Analysis : 12.03.2024 to 18.03.2024

5. Sample Collected By

:VCSPL Representative in presence of Client's Representative

Sl. No	Parameter	Unit	Testing Methods	Standard as per IS -10500:2012,	Analysis	Results
				Amd. 2015 & 2018	DW-1	DW-2
1.	Colour	Hazen	APHA 2120 B	5.0	20	<5,0
2.	Odour		APHA 2150B	Agreeable	Agreeable	Agreeable
3.	Taste		APHA 2160 C	Agreeable	Agreeable	Agreeable
4.	Turbidity	NTU	APHA 2130 B	1	7.3	<1.0
5.	pH Value (at 25 °C)	_	APHA 4500H B	6.5-8.5	7.85	8,32
6.	Total Hardness (as CaCO ₃) (max)	mg/L	APHA 2340 C	200	99.8	34.7
7.	Iron (as Fe) (max)	mg/L	APHA 3500 Fe B	1.0	0.44	0.32
8.	Chloride (as CI) (max)	mg/L	APHA 4500 C1 B	250.0	24.3	8.8
9.	Residual, free Chlorine (min)	mg/L	APHA 4500 CI B	0.2	ND	ND
10.	Dissolved Solids (max)	mg/L	APHA 2540 C	500.0	292	186
11.	Calcium (as Ca) (max)	mg/L	APHA 3500 Ca B	75.0	18.3	7.8
12.	Copper (as Cu) (max)	mg/L	APHA 3111 B,C	0.05	0.032	BDL
13.	Manganese (as Mn) (max)	mg/L	APHA 3500Mn B	0.1	BDL	BDL
14.	Sulphate (as SO ₄) (max)	mg/L	APHA 4500 SO ₄ ² - E	200.0	16.5	14.8
15.	Nitrate (as NO ₃) (max)	mg/L	APHA 4500 NO ₃ E	45.0	10.4	1,15
16.	Fluoride (as F) (max)	mg/L	APHA 4500 F,C	1.0	0.2	0.05
17,	Phenolic Compounds (as C ₆ H ₅ OH) (max)	mg/L	APHA 5530 B.D	0.001	BDL	BDL
18.	Mercury (as Hg) (max)	mg/L	APHA 3500 Hg	0,001	BDL	BDL
19.	Cadmium (as Cd) (max)	mg/L	APHA 3111 B,C	0.003	BDL	BDL
20.	Selenium (as Se) (max)	mg/L	APHA 3114 B	0.01	BDL	BDL
21.	Arsenic (as As) (max)	mg/L	APHA 3114 B	0.01	BDL.	BDL
22.	Cyanide (as CN) (max)	mg/L	APHA 4500CN C.D	0.05	BDL	BDL
23.	Lead (as Pb) (max)	mg/L	APHA 3111 B.C	0.05	BDL	BDL
24.	Zinc (as Zn) (max)	mg/L	APHA 3111 B,C	5.0	0.22	0.03
25.	Chromium (as Cr ⁻ ') (max)	mg/L	APHA 3500Cr B	_	BDL	BDL
26.	Mineral Oil (max)	mg/L	APHA 5520 B	0.5	ND	ND
27.	Alkalinity (max)	mg/L	APHA 2320 B	200.0	47.8	53.4
28.	Aluminium as Al (max)	mg/L	APHA 3500AI B	0.03	BDL	BDL
29.	Boron (max)	mg/L	APHA 4500 B.B	0.5	BDL	BDL
30.	Total Coliform (as TC)	MPN/100ml	APHA 9221 B	Shall not be	170	<1.8
31	E. Coli	MPN/100ml	APHA 9221 E	detectable in any — 100 ml Sample	Absent	<1.8
32.	Faecal Coliform (as FC)	MPN/100mI	APHA 9221 F		2.0	<1.8

BDL (Below Detectable Limits) Values: C6H5OH 0.05 mg l, Hg 0.002 mg l, Cd 0.005 mg l, Se 0.001 mg l, As 0.004 mg l, Pb 0.01 mg l, Zn 0.01 mg l, Cr 6 0.05 mg l, B 0.01 mg l. TC & FC : MPN 100 ml - f. f (0-0-0)





O Environmental & Social Study

isiontek Consultancy Services Pvt. Ltd.

(Committed For Better Environment)

Certified for : ISO 9001:2015, ISO 14001:2015, ISO 45001:2018

Accredited by: NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

O Infrastructure Enginering O Surface & Sub-Surface Investigation O Water Resource Management

OQuality Control & Project Management O Renewable Energy

O Agricultural Development Olnformation Technology OPublic Health Engineering

O Mine Planning & Design

O Mineral/Sub-Soil Exploration Microbiology Lab O Waste Management Services

Environment Lab Food Lab Material Lab Soil Lab Mineral Lab

Ref: Envlab/23-24/TR-00363

Date:30.03.2024

ETP WATER ANALYSIS REPORT MARCH -2024

1. Name of the Industry

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

2. Sampling Location

: W1: Plant ETP-Inlet

W2: Plant ETP-Outlet

3. Date of Sampling

: 11.03.2024

4. Date of Analysis

: 12.03.2024 to 18.03.2024

5. Sample Collected By

: VCSPL Representative in presence of Client's Representative

SL No	Parameter	Unit	Testing Methods	Inland Surface Water	Analysis	Results
			Testing Freehous	Standard Effluents Part-A	W-1	W-2
1.	Colour and Odour	Hazen	APHA 2120 B & APHA 2150B	5 & U/O	25 & Agreeable	<5.0 & Agreeable
2.	Suspended solids	mg/l	APHA 2540 D	100.0	4.8	2.2
3.	Particle size of suspended solids		APHA 2540 D	Shall Pass 850µ IS Sieve	passed	passed
4.	pH Value (at 25 °C)		APHA 4500H B	5.5-9.0	7.0	7.1
5,	Temperature	*C	APHA 2550 B	Shall not exceed 5°C above the receiving water Temp	25.8	25.6
6.	Oil and grease	mg/l	APHA 5520 B	10.0	3.4	1.3
7.	Total Residual Chlorine (as RFC)	mg/l	APHA 4500 Cl ⁻ B	1.0	ND	ND
8.	Ammonical Nitrogen (as NH3-N)	mg/l	APHA 4500 NH ₃ F	50.0	7.2	4.1
9.	Total Kjeldahl Nitrogen (as N)	mg/l	APHA 4500 N.egB	100.0	5.8	2.4
10.	Free ammonia (as NH ₃)	mg/l	By Calculation	5.0	ND	ND
11,	Biochemical Oxygen Demand (3 days at 27°C)	mg/l	APHA 5210 B	30.0	13.3	5.1
12.	Chemical Oxygen Demand	mg/l	APHA 5220 C	250.0	55.6	20.8
13.	Arsenic(as As)	mg/l	APHA 3114 B	0.2	BDL	BDL
14.	Mercury (As Hg)	mg/l	APHA 3500 Hg	0.01	BDL	BDL
15.	Lead (as Pb)	mg/l	APHA 3111 B.C	0.1	0.04	BDL
16.	Cadmium (as Cd)	mg/l	APHA 3111 B,C	2.0	BDL	BDL
17.	Hexavalent chromium (as Cr +6)	mg/l	APHA 3500Cr B	0.1	BDL	BDL
18.	Total chromium (as Cr)	mg/l	APHA 3111 B	2.0	BDL	BDI.
19.	Copper (as Cu)	mg/l	APHA 3111 B,C	3.0	0.01	BDL
20.	Zinc (as Zn)	mg/l	APHA 3111 B.C	5.0	0.21	BDL
21.	Selenium (as Se)	mg/l	APHA 3114 B	0.05	BDL	BDL
22.	Nickel (as Ni)	mg/l	APHA 3111 B	3.0	BDL	BDL
23.	Cyanide (as CN)	mg/l	APHA 4500 CN°C,D	0,2	BDL	BDL
24.	Fluoride (as F)	mg/l	APHA 4500 F C	2.0	0.67	0.45
25.	Dissolved phosphates (as P)	mg/l	APHA 4500 P.D	5.0	2.42	0.23
26.	Sulphide (as S)	mg/l	APHA 4500 S ² -D	2.0	0.43	ND
27.	Phenolic compounds (as C ₆ H ₅ OH)	mg/l	APHA 5530 B.D	1.0	0.12	BDL
28.	Bio-assay test	mg/l	APHA 10600 D	90% survival of fish after 96 hours in 100% effluent	80%	91%
29.	Manganese (as Mn)	mg/l	APHA 3500Mn B	2.0	BDL	BDL
30.	Iron (as Fe)	mg/l	APHA 3500Fe B	3.0	0.52	0.31
31.	Vanadium (as V)	mg/l	APHA 3500V B	0.2	BDL	BDL
32.	Nitrate Nitrogen (as N)	mg/l	APHA:4500 NO. B.	10.0	10.8	1.5

Note: CL: Colourless, U.O: Unobjectionable, ND: Not Detected.

BDI. (Below Detectable Limits) Values: C6H5OH 0.05 mg l. Hg 0.002 mg l. Cd 0.003 mg l. Se 0.001 mg l. CN 0.01mg l., As 0.004 mg l. Ph 0.01 mg l. Zn 0.05 mg l. Cr 6 0.01 mg l. B. 0.01 mg L.N. 0.05mg l. 1' 0.01mg l.





O Environmental & Social Study

isiontek Consultancy Services Pvt. Ltd.

O Agricultural Development

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018

Accredited by : NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

- Olafrastructure Enginering O Surface & Sub-Surface Investigation O Water Resource Management
 - O Quality Control & Project Management O Renewable Energy
- Olaformation Technology Public Health Engineering
- O Mine Planning & Design O Mineral/Sub-Soil Exploration

O Waste Management Services

Laboratory Services Environment Lab Food Lab Material Lab Mineral Lab Microbiology Lab

Ref: Envlab/23-24/TR-00364

Date:30.03.2024

STP WATER ANALYSIS REPORT MARCH-2024

1. Name of the Industry

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

2. Sampling Location :W1: Plant STP Inlet

W2: Plant STP Outlet

3. Date of Sampling 4. Date of Analysis

: 11.03.2024 : 12.03.2024 to 18.03.2024

Sample Collected By

: VCSPI. Representative in presence of Client's Re-

SI.	Parameter			Schedule-VI and new CPCB	Analysis	Results
No	Parameter	Unit	Testing Methods	norms (* standard as per G.S.R.1265(E)	W-1	W-2
I.	Colour and Odour	Hazen	APHA 2120 B& APHA 2150B	5 & U/O	25 & Pungent Smell	<5.0 & Agreeable
2.	Suspended solids	mg/l	APHA 2540 D	100.0*	8.2	3.0
3.	Particle size of suspended solids		APHA 2540 D	Shall Pass 850µ IS Sieve	passed	passed
4.	pH Value (at 25 °C)	NTU	APHA 4500HTB	6.5-9.0*	7.3	8.1
5.	Temperature	°C	APHA 2550 B	Shall not exceed 5°C above the receiving water Temp	25 9	25.8
6.	Oil and grease	mg/l	APHA 5520 B	10.0	1.2	ND
7.	Total residual chlorine	mg/l	APHA 4500 CI B	1.0	ND	ND
8.	Ammonical Nitrogen (as NH3-N)	mg/l	APHA 4500 NH ₃ F	50.0	9.3	6.2
9.	Total Kjeldahl Nitrogen (as N)	mg/l	APHA 4500 NongB	100.0	10.2	7.9
10.	Free ammonia (as NH ₃)	mg/l	By Calculation	5.0	ND	ND
11.	Biochemical Oxygen Demand (3 days at 27°C)	mg/l	APHA 5210 B	30.0*	12.25	4.2
12.	Chemical Oxygen Demand (as COD)	mg/l	APHA 5220 C	250.0	47.6	16.6
3.	Arsenic(as As)	mg/l	APHA 3114 B	0.2	BDL	BDL
4.	Mercury (As Hg)	mg/l	APHA 3500 Hg	0.01	BDL	BDL
5.	Lead (as Pb)	mg/l	APHA 3111 B.C	0.1	0.04	BDL
6.	Cadmium (as Cd)	mg/l	APHA 3111 B.C	2.0	BDL	BDL
7.	Hexavalent chromium (as Cr +6)	mg/l	APHA 3500Cr B	0.1	BDL	BDL
8.	Total chromium (as Cr)	mg/l	APHA 3111 B	2.0	BDL	BDL
9.	Copper (as Cu)	mg/l	APHA 3111 B,C	3,0	0.03	BDL
0.	Zinc (as Zn)	mg/l	APHA 3111 B,C	5.0	0,028	0.03
1.	Selenium (as Se)	mg/l	APHA 3114 B	0.05	BDL	BDL
2.	Nickel (as Ni)	mg/l	APHA 3111 B	3.0	BDL	BDL
3.	Cyanide (as CN)	mg/l	APHA 4500 CN C,D	0.2	BDL	BDL
4.	Fluoride (as F)	mg/l	APHA 4500 F C	2.0	2.3	0.6
5.	Dissolved phosphates (as P)	mg/l	APHA 4500 P.D	5.0	0.56	BDL
6.	Sulphide (as S)	mg/l	APHA 4500 S ² -D	2,0	0.25	ND
7.	Phenolic compounds (as C ₆ H ₅ OH)	mg/l	APHA 5530 B.D	1.0	BDL	BDL
8.	Bio-assay test	mg/l	APHA 10600 D	90% survival of fish after 96 hours in 100% effluent	77%	90%
9.	Manganese (as Mn)	mg/l	APHA 3500Mn B	2.0	BDL	BDL
0.	Iron (as Fe)	mg/l	APHA 3500Fe B	3.0	0.52	0.43
1.	Vanadium (as V)	mg/l	APHA 3500V B	0.2	BDL	BDL
2.	Nitrate Nitrogen (as N)	mg/l	APHA4500 NO; B	10.0	9.8	1.3
3.	Faecal Coliform (as FC)		APHA 9221 E	100	<1600	<1.8

BDI. (Below Detectable Limits) Fatures: C6H5OH 0.05 mg l. Hg 0.002 mg l. Cd 0.003 mg l. Se 0.001 mg l. CN 0.01mg l. As 0.004 mg l. Pb 0.01 mg l. Zn 0.05 mg l. Cr 6 0.01 mg l. B 0.01 mg l. Ni -0.05mg l. V 0.01mg l.





O Infrastructure Enginering

O Water Resource Management

O Environmental & Social Study

isiontek Consultancy Services Pvt. Ltd.

(Committed For Better Environment)

Certified for: ISO 9001:2015, ISO 14001:2015, ISO 45001:2018

Accredited by: NABET-A Grade, MOEF & CC/CPCB & SPCB-A Grade

- O Surface & Sub-Surface Investigation
- OQuality Control & Project Management O Renewable Energy
- O Agricultural Development Olnformation Technology OPublic Health Engineering
- O Mine Planning & Design
- O Mineral/Sub-Soll Exploration O Waste Management Services

Laboratory Services Environment Lab Food Lab Material Lab Soil Lab Mineral Lab Microbiology Lab

Ref: Envlab/23-24/TR-00365

Date:30.03.2024

STP WATER ANALYSIS REPORT MARCH-2024

Name of the Industry

: M/s GMR Kamalanga Energy Ltd, Dhenkanal

2. Sampling Location

:W3: Township STP Inlet W4: Township STP Outlet

3. Date of Sampling

: 11.03.2024

4. Date of Analysis

: 12.03.2024 to 18.03.2024

5. Sample Collected By

:VCSPL Representative in presence of Client's Representative

SI.	Do no market			Schedule-VI and new CPCB	Analysis	Results
No	Parameter	Unit	Testing Methods	norms (* standard as per G.S.R.1265(E)	W3	W4
l,	Colour and Odour	Hazen	APHA 2120 B& APHA 2150B	5 & U/O	25 & Pungent Smell	<5.0 & Agreeable
2.	Suspended solids	mg/l	APHA 2540 D	100.0*	32.8	7.2
3.	Particle size of suspended solids	-	APHA 2540 D	Shall Pass 850µ IS Sieve	passed	passed
4.	pH Value (at 25 °C)	NTU	APHA 4500H ⁺ B	6,5-9.0*	6.4	7.5
5.	Temperature	°C	APHA 2550 B	Shall not exceed 5°C above the receiving water Temp	26.1	26.5
6.	Oil and grease	mg/l	APHA 5520 B	10.0	2.2	ND
7.	Total residual chlorine	mg/l	APHA 4500 Cl' B	1.0	0.15	ND
8.	Ammonical Nitrogen (as NH3-N)	mg/l	APHA 4500 NH ₃ F	50.0	4.2	1.4
9.	Total Kjeldahl Nitrogen (as N)	mg/l	APHA 4500 NoogB	100.0	8.1	2.7
10.	Free ammonia (as NH ₁)	mg/l	By Calculation	5.0	ND	ND
11.	Biochemical Oxygen Demand (3 days at 27°C)	mg/l	APHA 5210 B	30.0*	13.4	5 0
12.	Chemical Oxygen Demand (as COD)	mg/l	APHA 5220 C	250.0	58.4	21.2
13.	Arsenic(as As)	mg/l	APHA 3114 B	0.2	BDL	BDL
14.	Mercury (As Hg)	mg/l	APHA 3500 Hg	0.01	BDL	BDL
15.	Lead (as Pb)	mg/l	APHA 3111 B,C	0.1	BDL	BDL
16.	Cadmium (as Cd)	mg/l	APHA 3111 B.C	2.0	BDL	BDL
17.	Hexavalent chromium (as Cr +6)	mg/l	APHA 3500Cr B	0.1	BDL	BDL
18.	Total chromium (as Cr)	mg/l	APHA 3111 B	2.0	0.05	BDL
19.	Copper (as Cu)	mg/l	APHA 3111 B,C	3.0	0.04	BDL
20.	Zinc (as Zn)	mg/I	APHA 3111 B,C	5.0	0.044	0.023
21.	Selenium (as Se)	mg/l	APHA 3114 B	0.05	BDL	BDL
22.	Nickel (as Ni)	mg/l	APHA 3111 B	3.0	BDL	BDL
23.	Cyanide (as CN)	mg/l	APHA 4500 CN'C,D	0.2	BDL	BDL
24.	Fluoride (as F)	mg/I	APHA 4500 F C	2.0	0.58	0.53
25.	Dissolved phosphates (as P)	mg/l	APHA 4500 P,D	5.0	0.75	BDL
26.	Sulphide (as S)	mg/l	APHA 4500 S ² -D	2.0	0.36	ND
27.	Phenolic compounds (as C ₆ H ₅ OH)	mg/l	APHA 5530 B.D	1.0	BDL	BDL
28.	Bio-assay test	mg/l	APHA 10600 D	90% survival of fish after 96 hours in 100% effluent	80%	91%
29.	Manganese (as Mn)	mg/l	APHA 3500Mn B	2.0	BDL	BDL
30.	Iron (as Fe)	mg/l	APHA 3500Fe B	3.0	0.65	0.55
31.	Vanadium (as V)	mg/l	APHA 3500V B	0.2	BDL	BDL
32.	Nitrate Nitrogen (as N)	mg/l	APHA4500 NO. B	10.0	2.18	1.41
33.	Faecal Coliform (as FC)	MPN/100ml	APHA 9221 E	100	160	<1.8

BDL (Below Detectable Limits) Values: C6H5OH 0.05 mg l. Hg 0.002 mg l, Cd 0.003 mg l, Se 0.001 mg l, CN 0.01mg l, As 0.001 mg l, Ph. 0.01mg l, Zn 0.05 mg l, Cr 6 0.01 mg l, B 0.01 mg l, No. 0.05mg l, V 0.01mg l

